

## **DISTRICT WATER TESTING LABORATORY, TARN TARAN**

Village Kakka Kandiala, Block -Tarn Taran District -Tarn Taran.  
dwtl1t1@gmail.com

To,

BABA DEEP SINGH PUBLIC SCHOOL  
Village Dehra Sahib , Tarn Taran

No.: DWTLTT/2324/00105      Dated : 25/07/2023

Subject :            Testing Reports of Water Samples.

Reference:           Your Letter/SRF No. Nil    Dated: 24/07/2023

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 24/07/2023. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Tarn Taran

D/A :                Test Report



**Authorized Signatory  
For, District Water Testing Laboratory  
Tarn Taran**

# DISTRICT WATER TESTING LABORATORY, TARN TARAN

Village Kakka Kandiala, Block -Tarn Taran District -Tarn Taran.

dwtltt1@gmail.com

TEST REPORT						
Name & Address of Customer : <b>BABA DEEP SINGH PUBLIC SCHOOL</b> Village Dehra Sahib , Tarn Taran			Customer Reference No.		No : Nil Dated : 24/07/2023	
			Sample Submitted by		Mr. Gursewak Singh	
			Date of Sample Receipt		24/07/2023	
			Analysis Starting Date		24/07/2023	
			Analysis completion Date		25/07/2023	
Discipline : <b>Chemical Testing</b>			Group: <b>Water</b>			
ULR No.:		TC103872300000181F		Sample Type :		Treated Water
Test Report No.:		DWTLTT/2324/00105		Date of Issue :		25/07/2023
Registration no.:		DWTLTT/REG2324/00203		Condition of Sample :		Unsealed
Collection Point:		Treatment Plant (RO/CWPP/ARP/HH Purifier)		Quantity/Type of Bottle:		1000 ml / Plastic Bottles
Scheme/Source:		Not Mentioned(Not Mentioned)		Location/Depth :		NA / NA
Village :		Not Mentioned		Habitation :		Not Mentioned
Block:		Chohla Sahib		District :		Tarn Taran
Latitude :		Not Mentioned		Longitude:		Not Mentioned
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	6.85	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-1993 ) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 1984) (RA 2017)
5	TDS	90	500	2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
6	Turbidity	0.02	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
7	Alkalinity	64	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
8	Hardness	56	200	600	mg/l	IS 3025 (Part 21- 2019) EDTA Method
9	Calcium	8.02	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium	8.75	30	100	mg/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method
11	Chloride	9.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. \* Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%



Mr. Pankaj Kumar  
Quality Manager  
Authorized Signatory  
For, District Water Testing Laboratory  
Tarn Taran

----- End of the Test Report -----

## Civil Surgeon Office Tarn Taran

No.CSTT


San/24/79

Date:

10/4/24

### To Whom It May Concern

This is to certify that we have inspected Baba deep Singh Public School.  
V.P.O Dehra Sahib Tarn Taran After inspecting their Toilets, and  
other rooms, we can certify that their Cleanliness and sanitation is good. Their water is  
Potable through RO system as per report of Rural Water Supply and Sanitation  
Department. This certificate is valid for one year from the date of issue. No Health  
Hazard is seen in the premises of the school. There are separate washroom for girls  
and boys.

  
**District Epidemiologist**  
**TARN TARAN**  
District Epidemiologist

Tarn Taran