

Civil Surgeon Office


Tarn Taran

No.CSTT 315

Date: 16-4-21

To Whom It May Concern

This is to certify that we have inspected **Baba Deep Singh Public School , Village Dera Sahib, District Tarn Taran**. After inspecting their Toilets, and other rooms, we can certify that their Cleanliness and sanitation is good. Their water is Potable through RO system as per report of rural water supply and sanitation department. This certificate is valid for one year from the date of issue. No Health Hazard is seen in the premises of the school.


District Epidemiologist
Tarn Taran.

District Epidemiologist
TARN TARAN

Hi Tech Multi District Water Testing Laboratory.
Water Supply & Sanitation Complex,
Near Jaura Phatak Amritsar.

ANALYSIS REPORT FOR THE PHYSICAL & CHEMICAL AND BACTERIOLOGICAL
EXAMINATION OF THE WATER SAMPLE


Particulars of Sample

1. Name of the Place: *Baba Deep Singh Public School* Block: *Chadani Sahid.*
2. Source of the sample: *R.O.*
3. Whether water chlorinated: *-*
4. Date of Collection: *16-4-21*
5. Name and designations of the officer who collected Sample: *Principal.*
6. Date and Time of Commencing of Examination: *16-4-21*

CHEMICAL TEST REPORT

Sr. No.	TEST	DESIRABLE LIMIT	PERMISSIBLE LIMIT	RESULT
1	Turbidity (NTU)	5.0	10	<i>0.1</i>
2	Color (Physically)			<i>6.5</i>
3	pH	6.5 to 8.5	No Relaxation	<i>6.5</i>
4	Total Dissolved Solids, PPM	500	2000	<i>50</i>
5	Alkalinity (as calcium carbonate) mg/L	200	600	<i>40</i>
6	Total Hardness (as Ca Co) mg/L	200	600	<i>-</i>
7	Residual Chlorine mg/L	0.2	1.0	<i>0.10</i>
8	Iron mg/L	0.3	No Relaxation	<i>0.10</i>
9	Flourides (as F) mg/L	1.0	1.5	<i>-</i>
10	Nitrate (as NO ₃) mg/L	45	No Relaxation	<i>-</i>
11	Bacteriological Examination	After 24 hrs to 48 hrs		
	Total Coliform			
	E.Coli			

The water is Potable/ ~~Not Potable~~ according to the parameter tested above.


 Chemist
 Hi Tech Multi Distt.
 Water Testing Laboratory
 Deptt. Of W/S & Sanitation,
 Amritsar.

1. Sample is not drawn by us unless otherwise stated.
2. Sample consumed in Testing.