

DISTRICT WATER TESTING LABORATORY, TARN TARAN

Village Kakka Kandiala, Block -Tarn Taran District -Tarn Taran.

dwtltt1@gmail.com

To,

BABA DEEP SINGH PUBLIC SCHOOL

Village Dehra Sahib , Tarn Taran

No.: DWTLT/2526/00413 Dated : 03/02/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 14 Dated: 02/02/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 02/02/2026. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Tarn Taran

D/A : Test Report



**Authorized Signatory
For, District Water Testing Laboratory
Tarn Taran**

DISTRICT WATER TESTING LABORATORY, TARN TARAN

Village Kakka Kandiala, Block -Tarn Taran District -Tarn Taran.

dwtltt1@gmail.com



TC-14756

TEST REPORT						
Name & Address of Customer : BABA DEEP SINGH PUBLIC SCHOOL Village Dehra Sahib , Tarn Taran			Customer Reference No.		No : 14 Dated : 02/02/2026	
			Sample Submitted by		Mr. Rajat Sharma	
			Date of Sample Receipt		02/02/2026	
			Analysis Starting Date		02/02/2026	
			Analysis completion Date		03/02/2026	
Discipline : Chemical Testing			Group: Water			
ULR No.:		TC147562600000025F		Sample Type :		Treated Water
Test Report No.:		DWTLT/2526/00413		Date of Issue :		03/02/2026
Registration no.:		DWTLT/REG2526/01350		Condition of Sample :		Unsealed
Collection Point:		Treatment Plant (RO/CWPP/ARP/HH Purifier)		Quantity/Type of Bottle:		1000 ml / Plastic Bottles
Scheme/Source:		Not Mentioned(Not Mentioned)		Location/Depth :		Dehra Sahib / NA
Village :		Not Mentioned		Habitation :		Not Mentioned
Block:		Chohla Sahib		District :		Tarn Taran
Latitude :		Not Mentioned		Longitude:		Not Mentioned
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	6.98@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	105@180°C	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.53@25°C	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO3)	76	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO3)	64	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	11.22	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	8.75	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	11.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Mr.Mohammad Naushad Alam
Quality Manager
Authorized Signatory
For,District Water Testing Laboratory
Tarn Taran

----- End of the Test Report -----